U

Samuel Wick R&M Service Solutions, Inc. swick@mservicesolutions.com Phone: (904) 386-4483 Corporate Office 7256 Westport PI, Ste A West Palm Beach Florida 33413



Street, Street

DATE: 11/4/2020

Address: 115 Spring Lake Boulevard, Sebring, Florida, 33876-6143

Attn: Spring Lake Improvement District - Clay Shrum

Email: Cshrum@springlakefl.com

Re: Fire Hydrant Maintenance

To Whom it may concern,

R&M Service Solutions LLC, had performed Fire Hydrant Maintenance throughout Spring Lakes Improvement District distribution system. Throughout the service R&M has some observations of fire hydrants that struggled with regular maintenance. It is to our best of knowledge that no to minimal maintenance was performed on fire hydrants within the District.

R&M strongly advises to perform fire hydrant maintenance on the entire distribution system every year and 50% of the valves every year to ensure a safe and reliable water source.

Thank you for choosing R&M Service Solutions to assist within your district.

Samuel Wick Sales Director

swick@rmservicesolutions.com

Samuel Wick

(904) 386-4483